

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1595:116 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Invensys Climate Controls Americas, 191 E. North Ave., Carol Stream, IL 60188-2064
Contact: Tom Barakat (630) 260-7262 Fax (630) 260-7290

DESIGN: Models 2650-760 and 2650-761 duct smoke detectors. All units are four-wire duct detectors. Model 2650-760 employs an ionization smoke detector head. Model 2650-761 employs a photoelectric smoke detector head.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VAC, 24 VDC, 115 VAC or 230 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as duct detectors for use with separately listed compatible fire alarm control units when installed in HVAC systems with air velocity between 500 and 4000 ft./min.

XLF: 3240-1004:105

NOTE: Formerly 3240-1093:126

02-06-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

FEBRUARY 6, 2003

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager